



- NOTES:**
- 250 WATTS LUMINAIRE @ STREET INTERSECTIONS OR IN FRONT OF INTERSECTION & 100 WATTS @ OTHER LOCATIONS.
  - #4 TIES TO BE @ 12" MIN. SEPARATION FROM TOP TO BOTTOM. SIDEWALL REBAR TO BE 3" OR MORE FROM EXCAVATION WALLS AND BOTTOM.
  - 1'-6" @ AREAS W/PARKWAY OR NO SIDEWALK, 5'-6" ELSEWHERE.
  - THIS DETAIL IS SUBJECT TO APPROVAL BY APPROPRIATE UTILITY AGENCY.
  - FOUNDATION CONCRETE TO BE 3500 PSI MIN. STRENGTH.
  - DRILL OR BORE INTO UNDISTURBED OR COMPACTED SOIL (95% OF MAX DRY DENSITY)



REVISION	DESIGN BY:	DRAWN BY:	DATE
ORIGINAL	AC/JAG	A.C./G.M.	07/02/07

APPROVED BY THE CITY OF EL CENTRO  
PUBLIC WORKS DEPARTMENT, ENGINEERING DIVISION

R.C.E. 62028

JOHN A. GAY, P.E.  
PUBLIC WORKS/ENGINEERING SENIOR ENGINEER

DATE

R.C.E. 24740

TERRY L. HAGEN, P.E.  
DIRECTOR OF PUBLIC WORKS/ENGINEERING

DATE

**CITY OF EL CENTRO**  
PUBLIC WORKS DEPARTMENT

**STREET LIGHT**

DWG NO. **EC-900**